

GOODWE · ESA INVERTER RESTART

Inverter Restart Guide

A full restart of your GoodWe ESA system takes around 10 minutes. Work through the Switch Off steps first, then the Switch On steps.

About 10 minutes

Inverter + battery

**Watch the video guide**

Prefer to watch? Follow along step by step on YouTube.

[Watch on YouTube](#)

STEP-BY-STEP

1 Switch off inverter AC supply**START HERE**

Switch off the inverter's AC supply at the switchboard or AC isolator.

**2 Press and hold the battery button**

Press and hold the battery button for more than 5 seconds.

**3 Turn off the battery isolators**

Switch the battery isolators to OFF.

**4 Turn off inverter DC switch**

Switch the inverter's DC switch to OFF to fully power down.

5 Switch battery isolators back on

Switch the battery isolators back to ON to begin start-up.

**6 Press and hold the battery button**

Press and hold the battery button again for more than 5 seconds.

**7 Turn inverter DC switch back on**

Switch the inverter's DC switch back to ON.

**8 Turn inverter AC supply back on**

Switch the AC supply back on. When the green power light is steady, the system is running.

✓ FINISHED